



Heat Network Quality Assurance

Richard Hanson-Graville

Technical Director, Heatweb Solutions Ltd.

Heat Network Quality Assurance

Why do we need QA?



NO
FISHING



Heat Network Quality Assurance

Is it possible to create effective quality assurance measures [for heat networks] without introducing the need for a 100% external inspections,

and the training of a workforce to perform those inspections?

What do we know that works ?

A single KPI, when on public display, motivates all stakeholders to improve quality themselves.


The BESA HIU Test Regime

“The [BESA] testing clearly shows performance differences between substations. The simplicity of the VWARD as a benchmark of substation performance is having an impact – with manufacturers starting to publicise the VWARD figure for their substations. Most of the manufacturers have made or brought forward planned substation improvements as a result of the testing.”

Martin Crane, Carbon Alternatives



**Substation E:
The DATA HIU**



VWARD with keep warm inactive *		
Period	VWARD (°C)	% Time
No heating	13.9	93%
Heating	39.4	7%
Overall	15.8	

* HIU has ability to deactivate keep warm function

VWARD calculation prepared by Freddie Valletta of FairHeat Ltd on 26 July 2017

Heat Network Quality Assurance

How do we shine a light on
poor efficiency in real-world
heat networks ?

Q1: Do the lights work?



Service KPIs (from HNTAS)

KPI Data Points	Days In Period	Devices Reporting (24h)	Points Operational (24h)	ARMS Connectivity (24h)
174	1	100%	100%	100%


Energy Centre Flow Temperatures	Avg Return Temp... ↗	Current Differential Pr...
Current Value 71.1 °C	Network 62.4 °C	block3 4.05 bar
Volume Weighted Average 71.1 °C	Boilers 71.6 °C	block8and9 270 mbar
Time Weighted Average 71.1 °C	Difference 9.12 °C	block4and5 180 mbar
Minimum 69.8 °C		
Variance 2.81 °C		

Substation KPIs


Substation Blocks 1 & 2 Tem... ↗	Substation Block 3	Substation Blocks 4 & 5 Te... ↗	Substation Blocks 8 & 9 Te... ↗
Current Value 70.3 °C	Current Value 69.6 °C	Current Value 72.4 °C	Current Value 76 °C
Volume Weighted Average 1 69.7 °C	Volume Weighted Average 1 70.1 °C	Volume Weighted Average 1 72.0 °C	Volume Weighted Average 1 70.0 °C
Volume Weighted Average 2 69.9 °C	Volume Weighted Return Temperature 1 69.2 °C	Volume Weighted Average 2 0 °C	Volume Weighted Average 2 74.4 °C
Avg Primary Return Temperature 1 45.1 °C	Avg Secondary Return Temperature 58.2 °C	Avg Primary Return Temperature 1 71.5 °C	Avg Primary Return Temperature 1 66.8 °C
Avg Primary Return Temperature 2 51.9 °C	PHE Efficiency 34.2%	Avg Primary Return Temperature 2 0 °C	Avg Primary Return Temperature 2 71.6 °C
Avg Secondary Return Temperature 43.9 °C		Avg Secondary Return Temperature 66.2 °C	Avg Secondary Return Temperature 67.5 °C
PHE 1 Efficiency 98.5%		PHE 1 Efficiency 20.7%	PHE 1 Efficiency 95.1%
PHE 2 Efficiency 71.0%		PHE 2 Efficiency 0%	PHE 2 Efficiency 54.5%

Block B Low Returns			Block B High Returns			Block C Returns			Block D Returns			Block E Returns		
phex1 57.4 °C	phex2 45.2 °C	meter 57.4 °C	phex1 69.6 °C	phex2 49.1 °C	meter 69.8 °C	phex1 59.3 °C	phex2 59.0 °C	meter 59.6 °C	phex1 58.9 °C	phex2 53.5 °C	meter 59.1 °C	phex1 56.9 °C	phex2 57.9 °C	meter 61.2 °C

Energy & Bypass KPIs



- blockd 22%
- blockc 18%
- Plantroom Losses 15%
- Primary Distribution Losses 13%
- blockblow 8%
- blockalow 7%
- blockahigh 6%
- blockbhigh 4%
- blockahotel 4%
- blocke 3%




Gas Boiler KPIs


Fuel Conversion Losses

15.3%

Gas Consumption



Heat Pump KPIs



24hr VWA

82.9 °C

23.3 °C

Period COP

2.00


In

44.1 kWh






Out

88.3 kWh


Storage Temperatures




Buffer & Thermal Store KPIs



Central Heating KPIs




Central Heating Graphics



11.5 °C

Return Temperature KPIs


Return Temperature East



Peak Return Tempera...

All zones within limits

Return Temperatures West



Peak Return Tem... ☒

tRZ2	39.2 °C
tRZ5	37.3 °C
tRZ6	36.1 °C
tRZ8	36.3 °C
tRZ9	37.1 °C

Water Quality KPIs

Current Values


Crevice corrosion 1 220 Ω	Crevice Corrosion 2 220 Ω	Conductivity 302	Calculated parameter- Corrosion rate 0.0100	Calculated parameter - Dosing 4.10	Calculated parameter - Metal loss 0.00300	Dissolved Oxygen 7.73	Galvanic Current 90 μA	pH 10.8
------------------------------	------------------------------	---------------------	---	--	---	--------------------------	---------------------------	------------

Conductivity quality 100%	Temperature 19.8 °C	Calculated parameter - Cumulative DO 7704	Calculated parameter - Cumulative GC 241	Dissolved Oxygen Quality 100%	Dissolved Oxygen Temperature 20.5 °C	Flow Count 1	Pressure 0.400	pH quality 30%	pH Temperature 19.9 °C
------------------------------	------------------------	---	--	----------------------------------	---	-----------------	-------------------	-------------------	---------------------------

Hevasure Aq...



Historic Status




Comments

System	2023-	
Commissioned	11-12	
	01:52:22	

Net-Zero KPIs

Gas Consumption [🔗](#)



Degree Days for Heating	2398 HDD
Percentage Saving	18.1%
Energy saving over period	1.20 GWh
Fuel saving over period	£60.2K
Carbon Saving	250 Tonnes CO2


BMS Focused Quality Assurance

Data


net 	node  	device 	vargroup 	varkey 	value 
city...	energycentre	boiler3	driver	module2enable	true
city...	energycentre	lthwPumps	driver	enable	true
city...	energycentre	boiler4	digin	module2Fault	true
city...	energycentre	chw-pump1	driver	speed	100.0
city...	energycentre	chiller1	sensor	tInlet	10.98
city...	energycentre	chiller2	sensor	tInlet	7.56
city...	energycentre	boiler3	sensor	tFlue	26.45
city...	energycentre	boiler1	driver	module1enable	true
city...	energycentre	boiler1	digin	module2Run	false
city...	energycentre	boiler4	digin	module1EndSw	true
city...	energycentre	chw	sensor	tRPrim	7.8
city...	energycentre	condenser	sensor	tR	20.35
city...	energycentre	lthw	sensor	dpPrimMin	-0.38
city...	energycentre	boiler4	digin	module2Run	false
city...	energycentre	pu	digin	highPress	true
city...	energycentre	pu	digin	lowPress	true



Message Queuing Telemetry & Transport (MQTT)



Database and Structured Query Language (PostgreSQL)




Standardised Labelling & Query Functions

```
SELECT fn_weighted_average('my_site','sitewide','meter','tR','m3h',$__timeFrom(), $__timeTo()) as vwaft,
```



Visibility (Grafana)



Dashboards

Block C BMS Data



Connectivity
KPIs



DHW Consumption



Energy
KPIs



Energy Centre BMS Data



Gas Consumption



▼ Sitewide KPIs

Energy Centre Flow Temperatures

Volume Weighted Average 77.1 °C

Time Weighted Average 77.1 °C

Minimum 63.7 °C

Variance 17.7 °C

Buffer Utilisation

Buffer 1
82.0%

Buffer 2
94.2%

Buffer 3
98.9%

Energy Centre Return Temperatures

Volume Weighted Average 60.7 °C

Time Average 60.9 °C

Gas Consumption

1495 m³

16.6 MWh

2.85 tCO₂

Sitewide Volume

733 m³

Volume Delivered

648 m³

Primary Bypass Volume

84.7 m³

11.6%

Time Average PHEX Secondary Temperatures

62 62 62 62 76 67 65 59 62 62 62 62 62 62

Sitewide Energy

13.7 MWh

Energy Delivered

11.7 MWh

EC Electrical Energy

184 kWh

Gas Consumption



Plantroom Losses

2.90 MWh

Primary Network Losses


2.0 MWh

14.8%

Fuel Conversion Losses

17.5%

Energy Delivered to Blocks



Operational Alerts (Grafana)

Rules that determine whether an alert will fire

Search by data sources ⓘ

All data sources

State

Firing

Normal

Pending

Rule type

Alert

Search ⓘ

Q Search

1 rule 1 normal

Grafana

Alarms > standard

1 normal

1m

1

Email

Alertmanager

Cisco Webex Teams

DingDing

Discord

Email

Google Hangouts Chat

Kafka REST Proxy

LINE

State	Name	Health	Summary	Next evaluation	Actions
> Normal	Network Flow Temperature LOW	ok		in a few seconds	   

Organisation & User Management (Grafana)

Manage settings for this specific org.

Edit organization

Name

Update

Invite user

Send invitation or add existing Grafana user to the organization. [Heatweb Demo](#)

Email or username

Name

Role

Viewer **Editor** Admin

Send invite email



Submit

Back

RHG@heatweb.co.uk

Manage settings for an individual user.

User information

Name	Richard Hanson-Graville
Email	RHG@heatweb.co.uk
Username	RHG@heatweb.co.uk
Password	*****

Delete user

Disable user

Permissions

Grafana Admin	No
---------------	----

Organizations

Heatweb Demo	Viewer
--------------	--------

Open-Source Software (OSS)



Ask an AI, “Which companies use PostgreSQL?”

Made possible through Collaboration

 heatweb / HNQAP

 Apache-2.0 license

heatweb / HNQAP

Type to search

+ 🔍 📧 🏠

<> Code 2 Issues Pull requests Actions Projects Wiki Security Insights Settings

 HNQAP Public  Pin  Unwatch 1  Fork 1  Star 3

main 1 Branch 1 Tags

Go to file t Add file <> Code

heatweb Update functions.sql f4e1586 · 4 days ago 152 Commits

bms	Update README.md	4 months ago
browserware	Create README.md	3 months ago
grafana	Add files via upload	5 days ago
postgresql	Update functions.sql	4 days ago
qa	Add files via upload	3 months ago
qr	Add files via upload	5 months ago
LICENSE	Create LICENSE	3 months ago
README.md	Update README.md	3 months ago

About

Heat Network Quality Assurance Publications

Readme

Apache-2.0 license

Activity

3 stars

1 watching

1 fork

Releases 1

First release Latest

last week

**Heat
Network
Quality
Assurance
Publications**

What does the Governor say ?

“On some measures we only have 10 years left at current emissions rates before we have blown through 1.5 degrees of warming and moved to more catastrophic levels.”

“We all know that what gets measured gets managed. Climate change is not yet consistently measured, although the private sector has moved in this direction since Paris. We now need to make measurement and disclosure mandatory.”



Mark Carney
Governor of The Bank of England
2013 to 2020

How can .gov help ?

- Set a deadline of up to 2 years for ALL heat network ECs and Substations to be MQTT connected [to Ofgem] and publishing HNTAS KPIs.
- Provide grants of £5000 per site to upgrade BMS [head end] systems for connectivity.
- Make Open-Source Collaboration a centre-piece of quality control and net-zero technical standards.